TOWN OF FOXBOROUGH

BOARD OF HEALTH
SEPTIC SYSTEM REGULATIONS

The Board of Health of the Town of Foxborough, Massachusetts acting under the authority of Chapter 111, section 31, of the Massachusetts General Laws and amendments and additions thereto, enabling and acting thereunder and in accordance therewith have; in the interest of and for the preservation of the public health, duly made and adopted the following additional requirement to the State Environmental Code 310 CMR 15.00 (Disposal Works Applications applied for after March 30, 1995):

15.02: (8) Certificate of Compliance. Upon installation of the septic system a certified "As-Built" plan shall be submitted to the Board of Health prior to the issuance of the Certificate of Compliance and the Occupancy permit.

15.03:(4)(a) Percolation Tests may be performed at any time of the year. Groundwater may be determined by direct observation from February 1st through May 31st. Otherwise it must be determined by us using a combination of soil mottling and USGS well comparison (i.e., "Frimpter" method.)

13.03: (7) Distances.

Component	Septic Tank (Feet)	Leaching Area (Feet)
Property line	10	10
Surface water, supplies, etc.	100	150
Watercourses, etc.	100	150

TOWN OF FOXBOROUGH

BOARD OF HEALTH

SEPTIC SYSTEM REGULATIONS

The Board of Health of the Town of Foxborough, Massachusetts acting under the authority of Chapter 111, Section 31, of the Massachusetts General Laws and amendments and additions thereto, enabling and acting thereunder and in accordance therewith have; in the interest of and for the preservation of the public health, duly made and adopted the following additional requirement to the State Environmental Code 310 CMR 15.00:

15.11: (3) Leaching Pits - Ground Water. Leaching pits shall not be installed in areas where the maximum ground water elevation is less than 6 feet below the bottom of the excavation.

15.12: (2) Leaching Galleries - Ground Water. Leaching galleries shall not be installed where the maximum ground water elevation is less than 6 feet below the bottom of excavation.

15.13: (2) Leaching Chambers - Ground Water. Leaching chambers shall not be installed where the maximum ground water elevation is less than 6 feet below the bottom of the excavation.

15.14: (2) Leaching Trenches - Ground Water. Leaching trenches shall not be installed where the maximum ground water elevation is less than 6 feet below the bottom of the excavation.

15.15: (3) Leaching Fields - Ground Water. Leaching fields shall not be installed where the maximum ground water elevation is less than 6 feet below the bottom of the excavation.

These regulations are effective January 1, 1994 and shall pertain to only Zone II Aquifer Protection areas. All other systems shall not be installed where maximum ground water is less then 5 feet below the bottom of the excavation.